



SERVICE TEES ARE PERMITTED IF

- A.** SHOWN ON AN APPROVED SET OF CONSTRUCTION PLANS.
- B.** 4" MINIMUM BRANCH AND SERVICE LINE WITH GATE VALVE WITHIN 3' OF MAIN.

NOTE

- A.** METER SHALL BE LOCATED INSIDE THE BUILDING.



**CITY OF
SIDNEY**

**4" AND LARGER WATER MAIN SERVICE
CONNECTION (DOMESTIC)**

REVISIONS:

DATE

APPROVED:
FEB. 2002

PAGE No.

800-12