

# **Clarification #1**

To drawings and specifications for

## **Maple Street Sewer Replacement for the City of Sidney**

Please find attached a copy of the flow rate, velocity, and direction of flow for the Maple Street Sewer Replacement project.

Maple at St. Marys

E6-8-24

8" VCP

1.76" Level

0.54 Velocity

0.020 MGD

E6-8-27

MAPLE

ST  
MARYS

E6-8-22

E6-8-24

OAK

GROVE

E6-8-22

West and Maple

1.98" Level

0.64 Velocity

0.025 MGD

WEST