



SERVICE TEES ARE PERMITTED IF

- A. SHOWN ON AN APPROVED SET OF CONSTRUCTION DRAWINGS.
- B. 4" MINIMUM BRANCH AND SERVICE LINE WITH GATE VALVE WITHIN 3' OF MAIN.
- C. 6" FIRE LINE MAY HAVE A ONE-INCH DOMESTIC TAP AND 8" FIRE LINE MAY HAVE A 1-1/2" DOMESTIC TAP. ALL DOMESTIC TAPS MUST BE INSTALLED BEFORE THE FIRE SPRINKLER RISER.

6" AND LARGER FIRE LINE SERVICE
(METER REQUIRED)

WALL/POST INDICATOR VALVES SHALL BE ADDED ON PREMISES AT FIRE DEPARTMENT REQUEST



**CITY OF
SIDNEY**

FIRE LINE DETAILS

REVISIONS:

DATE APPROVED:
06/03/2020
PAGE No.
800-19